



Water Supply District of Acton

693 MASSACHUSETTS AVENUE
P.O. BOX 953
ACTON, MASSACHUSETTS 01720

TELEPHONE (978) 263-9107

FAX (978) 264-0148

DATE: 12/30/2009

TO: Town of Acton Building Department

FROM: Chris Allen, District Manager

RE: Comments on Michele Circle

1. All water mains, services, appurtenances and installation of such must comply with AWD specifications. (Hard copy may be picked up at AWD main office)
2. A proposed "As-Built" plan of the water infrastructure must be submitted, reviewed and approved by AWD prior to any installation of said infrastructure.
3. All water related infrastructure must be inspected by AWD personnel prior to backfill.
4. To avoid potential long-term water quality issues, AWD recommends the main water line from Main Street be 2" High Density Polyethylene (HDPE) manifolded to two 1" HDPE lines, one feeding each single family home.
5. A final "As-Built" plan denoting exact locations of all water infrastructure will be submitted by the contractor prior to filling of any water mains for pressure test or disinfection per AWD specifications.

Respectfully submitted

Chris Allen
District Manager